

certificate

The applicant:

ROPRE S.A.

Parque Industrial, Rua M, lote 15
6200-027 CANHOSO - COVILHA

is authorized to place the label "Certificate of Reaction to Fire of Construction Products" according to the report Nº 2009AN0870



aitex

**CERTIFICATE OF REACTION
TO FIRE OF:**

CONSTRUCTION PRODUCTS

Nº 09AN0870

The reference

"BOLTHERM REFLECTIVO"

has been tested according to the standards UNE-EN ISO 11925-2:2002 and UNE-EN 13823:2002. The classification according to standard UNE-EN 13501-1:2007 is:

"B_{s1,d0}"

This certificate has validity until the February 3rd 2014

Alcoy, February 4th 2009.



Raquel Muñoz González
CHIEF OF LABORATORIES AREA



Jordi Feli Pascual
HEAD OF FIRE DEPARTMENT

